

FIRE PREVENTION DIVISION RECOMMENDED DAILY NIGHTCLUB CHECKLIST

| | | | 11/19 | 9/2012 |
|-----------------------|-----------------|-------------------------------|----------------------------------|--------|
| Business Name | | Address | | |
| Number of Exits | Date | Checked by | | |
| While not intended to | be an all inclu | usive list, the following ite | ems should be checked on a daily | |

| OCCUPANT LOAD | YES | NO | LOCATION |
|---|-----|----|----------|
| 1. Is Occupant Load posted in a conspicuous location? | | | |
| 2. Do you have a reliable means of counting and trained staff at | | | |
| the door? | | | |
| 3. Are there crowd managers present? (1 Crowd Manager for | | | |
| every 250 persons is required) | | | |
| EGRESS ARRANGEMENT | | | |
| 1. Do aisles & access ways have adequate widths? | | | |
| 2. Are aisles clear & unobstructed? | | | |
| 3. Are aisles & access ways clear of "Trip Hazards"? | | | |
| 4. Are exit signs visible from anywhere in the club? | | | |
| 5. Are exit signs lit properly? | | | |
| EXITS & EXIT DOORS | | | |
| 1. Are exits clear & unobstructed? Check the path to the exit | | | |
| door, the exit stair (if applicable), and the path all the way to the | | | |
| public street or alley. | | | |
| 2. Are exits clear of "Tripping Hazards"? | | | |
| 3. Do exit doors have approved/required hardware? | | | |
| 4. Do doors require less than 15-lb. force to release latch? | | | |
| 5. Are exits lit properly? | | | |
| FIRE ALARM & OTHER FEATURES | | | |
| 1. Is Fire Alarm panel clear? | | | |
| 2. Are drapes/decorations flame retardant? | | | |
| 3. Are fire extinguishers visible, accessible, and charged? | | | |
| STAIR ENCLOSURES | | | |
| 1. Are stairs clear & unobstructed? | | | |
| 2. Are stairs free of "Trip Hazards"? | | | |
| 3. Are handrails firmly attached? | | | |
| 4. Are doors self-closing & self-latching? | | | |
| 5. Are stairs lit properly? | | | |

COMMENTS/CORRECTIONS:

Revision 2: 3/2010